

# SS 1 – Automatic Systems For Fire Suppression

<b>Address:</b>			
<b>Provided by (name):</b>			
<b>Equipment register</b>			
<b>No.</b>	<b>Make (major components)</b>	<b>Model</b>	<b>Location</b>
1			
2			
3			
4			
<b>Performance/Installation Standard:</b>	<input type="checkbox"/> NZS 4541 Year: <input type="checkbox"/> 2013 <input type="checkbox"/> 2007 <input type="checkbox"/> 2003 <input type="checkbox"/> NZS 4515 Year: <input type="checkbox"/> 2009 <input type="checkbox"/> 2003 <input type="checkbox"/> AS 1851:2005 <input type="checkbox"/> Specifically Designed Solution _____ <input type="checkbox"/> Other (historical) _____		
<b>Inspections &amp; Maintenance Standard:</b>	<input type="checkbox"/> NZS 4541 Year: <input type="checkbox"/> 2013 <input type="checkbox"/> 2007 <input type="checkbox"/> 2003 <input type="checkbox"/> NZS 4515 Year: <input type="checkbox"/> 2009 <input type="checkbox"/> 2003 <input type="checkbox"/> AS 1851:2005 <input type="checkbox"/> Specifically Designed Solution _____		
<b>As a minimum these inspections and maintenance procedures will be carried out:</b>	Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.		
<b>Equipment Requiring Weekly Maintenance:</b> If ticked weekly inspections are required.	<input type="checkbox"/> Building contains Diesel Fire Pump <input type="checkbox"/> Building contains an Electric Fire pump without an alarm <input type="checkbox"/> Building contains a Direct Connection to the Fire Department that requires weekly maintenance		
<b>Inspection frequency and responsibility:</b>	<input type="checkbox"/> Weekly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP	
	<input type="checkbox"/> Monthly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP	
	<input type="checkbox"/> Annually	<input type="checkbox"/> Owner <input type="checkbox"/> IQP	
	Where the system is connected to the buildings emergency warning system, testing of the interface between the two systems should be carried out annually.		
<b>As a minimum these reporting procedure will be carried out:</b>	The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: <ul style="list-style-type: none"> <li>• Details of any inspection, test or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work.</li> <li>• A Form 12A provided by an IQP annually</li> </ul>		