

# SS 6 – Riser Mains

<b>Address:</b>					
<b>Provided by (name):</b>					
<b>Equipment register</b>					
	<b>Make</b>	<b>Model</b>	<b>Location</b>	<b>Dry tick</b>	<b>Wet tick</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
<b>Installation Standard:</b>		<input type="checkbox"/> NZS 4510:2008 <input type="checkbox"/> Specifically Designed Solution _____ <input type="checkbox"/> Other (Historical) _____			
<b>Inspections and Maintenance Standard:</b>		<input type="checkbox"/> NZS 4510:2008 <input type="checkbox"/> Specifically Designed Solution _____ <input type="checkbox"/> Other (Historical) _____			
<b>As a minimum these inspections and maintenance procedures will be carried out:</b>		Planned preventative maintenance and responsive maintenance should be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.			
<b>Inspection frequency and responsibility:</b>		<input type="checkbox"/> Daily		<input type="checkbox"/> Owner	
		<input type="checkbox"/> Monthly		<input type="checkbox"/> IQP	
		<input type="checkbox"/> Annually		<input type="checkbox"/> Owner	
				<input type="checkbox"/> IQP	
<b>As a minimum these reporting procedure will be carried out:</b>		The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: <ul style="list-style-type: none"> <li>• Details of any inspection, test or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work.</li> <li>• A Form 12A provided by an IQP annually</li> </ul>			